

No. PH/Water/BAC-1158/2025-26
 GOVERNMENT OF KARNATAK

Office of Joint Director
 Public Health Institute,
 Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date: 18/11/2025

Sample No	Source & Particulars of Water Sample	Opinion						
		M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC	
3688	Poorna Pratha High School Borewell	160	-	Neg	-	NSPP	-	
3689	KMVI Thota RO Plant	Nic	-	-	SPP	-	-	
3690	Alliala Samra RO Plant	Nic	-	-	SPP	-	-	
3691	Judicial layout RO	Nic	-	-	SPP	-	-	
3692	Kanaka Nagar RO	Nic	-	-	SPP	-	-	
3693	Anjaneya Temple Alliala Samra RO Plant	Nic	-	-	SPP	-	-	


Medical Officers
 PHC
 MS Pappa
 Bangalore-07

Note:
 M.P.N. Count:
 Most Probable number of Bacteria Per 100ml of Water
 D.C. Test:
 Differential Coliform test
 Plate Count:
 Plate Count per ml of sample
 S.P.P:
 Water is satisfactory for Potable purpose
 N.S.P.P:
 Water is not satisfactory for Drinking purpose
 NSPP & FC:
 Water is not satisfactory for Drinking purpose and F. Coli found

Principal


POORNAPRAJNA HIGH SCHOOL
 YELAHANKA NEW TOWN,
 BANGALORE-560 061

HON. SECRETARY
 POORNAPRAJNA EDUCATION CENTRE
 YELAHANKA NEW TOWN
 BANGALORE - 560 064

For Joint Director (Labs)

 PUBLIC HEALTH INSTITUTE,
 Bengaluru